



基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位: dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
10001	49.1	57.5	56.4	50.8	48.8	50.5	50.2	48.8
10002	49.7	52.3	53.8	49.9	48.4	50.8	49.7	47.7
10003	51.8	55.2	56.0	52.2	49.2	51.6	49.4	49.1
10004	56.6	51.9	49.3	48.4	50.4	54.7	49.1	47.9
10005	50.6	55.0	57.5	47.3	49.7	53.7	56.1	51.8
10006	60.4	59.9	59.9	54.9	63.6	54.5	54.3	53.1
10007	63.1	58.8	57.9	53.3	62.9	61.0	57.5	54.1
10008	55.4	54.0	53.2	53.8	51.2	50.1	53.8	54.1
10009	50.6	55.4	58.0	46.9	49.6	53.7	55.9	51.9
10010	59.3	63.0	56.4	54.4	58.5	61.2	55.7	50.5
10011	58.2	63.1	50.8	50.4	58.0	55.5	53.4	48.9
10012	55.4	53.1	53.1	53.7	51.1	53.0	53.8	53.1