

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS mg/L	生化需氧量 BOD mg/L	化學需氧量 COD mg/L	溫度 °C	pH
偵測極限			1	1	0.90	-	-
保證值			20	20	50	-	6~9
11001	2021/01/07	上旬	4.8	ND	3.5	21.0	7.4
	2021/01/18	下旬	2.6	ND	4.7	19.6	7.5
11002	2021/02/01	上旬	1.6	ND	2.8	21.0	7.5
	2021/02/17	下旬	2.3	ND	2.3	22.7	7.9
11003	2021/03/04	上旬	2.4	ND	ND	22.6	7.4
	2021/03/18	下旬	2.6	1.2	2.0	23.2	7.4
11004	2021/04/08	上旬	4.0	1.6	2.5	25.2	6.9
	2021/04/15	下旬	3.0	ND	1.6	23.5	7.0
11005	2021/05/06	上旬	2.6	ND	5.3	25.0	8.6
	2021/05/17	下旬	2.9	ND	8.1	28.4	8.0
11006	2021/06/03	上旬	2.4	ND	3.7	30.1	7.5
	2021/06/17	下旬	3.3	1.2	3.0	31.8	7.2
11007	2021/07/08	上旬	3.0	ND	ND	32.6	7.4
	2021/07/19	下旬	4.6	ND	2.6	33.7	7.1
11008	2021/08/05	上旬	5.0	ND	2.5	31.4	7.3
	2021/08/16	下旬	3.0	ND	6.7	30.7	7.4
11009	2021/09/02	上旬	3.8	ND	3.7	32.1	7.4
	2021/09/16	下旬	6.8	ND	2.6	31.5	7.3
11010	2021/10/07	上旬	2.2	ND	5.1	31.3	6.6
	2021/10/18	下旬	1.5	ND	2.4	27.8	7.6
11011	2021/11/04	上旬	6.2	ND	2.8	26.2	6.5
	2021/11/15	下旬	3.0	ND	5.3	25.8	6.3
11012	2021/12/02	上旬	1.4	ND	4.1	23.8	7.4
	2021/12/16	下旬	2.8	ND	4.7	24.1	7.4