



基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位: dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值 單位: dB(A)	65	70	65	55	65	70	65	55
10301	53.5	52.5	52.8	52.8	52.8	52.6	52.6	52.3
10302	48.2	48.8	52.5	49.3	48.8	48.9	49.4	50.2
10303	54.4	56.1	56.1	50.9	52.7	54.8	55.7	52.1
10304	54.5	57.5	53.3	54.6	51.5	53.3	54.9	54.3
10305	62.6	63.0	58.2	53.4	56.3	49.1	54.0	44.8
10306	58.9	58.6	56.3	54.8	57.2	57.7	56.6	54.4
10307	53.8	66.0	51.8	49.8	56.4	63.5	54.2	50.6
10308	60.9	62.4	57.4	51.5	53.6	58.5	53.6	51.2
10309	54.0	49.1	59.2	50.3	54.9	59.6	56.6	50.0
10310	54.6	64.2	58.5	49.6	58.9	60.6	54.9	51.9
10311	52.8	51.8	53.2	53.7	47.1	49.7	51.6	48.1
10312	57.5	60.3	58.0	54.7	58.5	61.4	57.7	54.0